

PANELBOARD DP
200 AMP MAIN CIRCUIT BREAKER
SHORT-CIRCUIT RATING 10,000
Branch breakers to be bolt on type, panelboard to be approved for service entrance use.

TYPE DISTRIBUTION PANEL
208/120 VOLTS
RMS AMPERES SYMMETRICAL
REMARKS:

MOUNTED SURFACE
3 PHASE
4 WIRE

BRANCH CIRCUITS											
CIRC. No.	CIRCUIT DESIGNATION	CIRC. BKR.			BRCH WIRE SIZE	CIRC. No.	CIRCUIT DESIGNATION	CIRC. BKR.			BRCH WIRE SIZE
		POLE	TRIP	FRAME				POLE	TRIP	FRAME	
1	Circuits	3	70	100	4	2	Aeration Pump	2	25	100	10
3	-	-	-	-	-	4	-	-	-	-	-
5	-	-	-	-	-	6	Well Pump	2	15	100	12
7	Arch Lighting	3	40	100	8	8	-	-	-	-	-
9	-	-	-	-	-	10	Lighting Control	1	20	70	12
11	-	-	-	-	-	12	Spare	1	20	70	-
13	Spare	1	20	70	-	14	Spare	1	20	70	-
15	Spare	1	20	70	-	16	Spare	1	20	70	-
17	Space & Prov	1	-	70	-	18	Space and Prov	1	-	70	-
19	Space & Prov	1	-	70	-	20	Space and Prov	1	-	70	-
21	Space & Prov	1	-	70	-	22	Space and Prov	1	-	70	-
23	Space & Prov	1	-	70	-	24	Space and Prov	1	-	70	-
25						26					
27						28					
29						30					
31						32					
33						34					
35						36					
37						38					
39						40					
41						42					

PANELBOARD LP1
100 AMP MAIN Lugs Only
SHORT-CIRCUIT RATING 10,000
Breakers to be Bolt on Type

TYPE Lighting Panel
208/120 VOLTS
RMS AMPERES SYMMETRICAL
REMARKS:

MOUNTED Surface
3 PHASE
4 WIRE

BRANCH CIRCUITS											
CIRC. No.	CIRCUIT DESIGNATION	CIRC. BKR.			BRCH WIRE SIZE	CIRC. No.	CIRCUIT DESIGNATION	CIRC. BKR.			BRCH WIRE SIZE
		POLE	TRIP	FRAME				POLE	TRIP	FRAME	
1	LTG CKT #1	3	30	100	2	2	LTG CKT #2	3	30	100	2
3	--	-	-	-	-	4	--	-	-	-	-
5	--	-	-	-	-	6	--	-	-	-	-
7	LTG CKT #3	3	30	100	2	8	SPARE	3	30	100	--
9	--	-	-	-	-	10	--	-	-	-	-
11	--	-	-	-	-	12	--	-	-	-	-
13						14					
15						16					
17						18					
19						20					
21						22					
23						24					
25						26					
27						28					
29						30					
31						32					
33						34					
35						36					
37						38					
39						40					
41						42					

SUBMITTED
[Signature]
DRAWN BY: *R. E. Moski*
CHECKED BY: *E. R. O. K.*
SCALE: None

APPROVED
[Signature]
DAYBOOK NO. 010858
DATE 8/20/83

APPROVED
[Signature]
DRAWING NO. E-8

CITY OF HARTFORD
DEPARTMENT OF PUBLIC WORKS
FACILITY SERVICE BUREAU

cabm
CONSULTING ENGINEERS AND PLANNERS
20 Alexander Drive, Wallingford, Ct. 06492

BUSHNELL PARK PATHWAY
LIGHTING

PANEL BOARD SCHEDULE

Designed by: J. E. P.
Drawn by: R. E. Moski
Checked by: *YMM*
Approved by: *E. R. O. K.*

Scale: NONE
Date: AUG. 1983
Dwg. No. 8 of 8
Dwg. No. 8