



Minimum cover in stem and counterforts shall be 3"
Minimum cover for steel in base shall be 4"
Furnishing bending and placing steel reinforcement
will be paid for under Item No.
for additional steel reinforcement details see
Sheets No. 50 to 53 inclusive

CONNECTICUT RIVER FLOOD CONTROL

NORTH MEADOWS DIKE
FISCAL YEAR 1939 SECTION

R. R. STOP-LOG STRUCTURE NO. 1
STEEL REINFORCEMENT NO. 1
HARTFORD, CONN.

CONNECTICUT RIVER		HARTFORD, CONN.		CONNECTICUT	
IN 66 SHEETS	SCALE: 1/4 IN. = 1 FT.			SHEET NO. 49	
5	0			10	

U. S. ENGINEER OFFICE, PROVIDENCE, R. I., MAY 1939

SUBMITTED: Harold B. Fisher APPROVAL RECOMMENDED: 28 Burns APPROVED: [Signature]
SENIOR ENGINEER PRINCIPAL ENGINEER DIST. COL., CORPS OF ENGINEERS
HEAD, DESIGN SECTION CHIEF F. C. ENGINEERING DIV. DISTRICT ENGINEER

HEAD, DESIGN SECTION	CHIEF F. C. ENGINEERING DIV.	DISTRICT ENGINEER
DESIGNED: <i>J. C. Dingwall</i> ASSOC. ENGINEER	DRAWN: H.E.W. TRACED: A.J.H. CHECKED: CWB	FILE NO. CT-4-1707

12/31/45	As-Built		
DATE	REVISION	REV. BY	CK. BY AP. BY