


TORO AUTOMATIC IRRIGATION SYSTEM

BUSHNELL PARK



LEGEND

- ① - TORO 814-02-13 CHECK-O-MATIC SPRINKLER
- ② - TORO 814-02-11 CHECK-O-MATIC SPRINKLER
- ③ - TORO 812-02-11 CHECK-O-MATIC SPRINKLER
- ④ - TORO SUPER 800 FULL CIRCLE 5.0 SPRINKLER
- ⑤ - TORO SUPER 800 PART CIRCLE 2.5 SPRINKLER
- ⑥ - TORO SUPER 800 PART CIRCLE 1.3 SPRINKLER
- ⑦ - TORO 570-3P SPRAY HEAD
- ⑧ - TORO 252-03-03 ELECTRIC VALVE WITH SHUT-OFF
- ⑨ - TORO 252-03-03 ELECTRIC VALVE WITH SHUT-OFF
- ⑩ - TORO QUICK COUPLER VALVE
- > 1 - CAST IRON RING-TITE SHUT-OFF VALVE (SAME SIZE AS MAIN)
- (C) - TORO COMMERCIAL SERIES CONTROLLER
- (W) - WATER SOURCE (12" MAIN AT 95 PSI STATIC)
- (M) - WATER METER (SIZED AND SUPPLIED BY M.D.C.)
- (B) - FEDCO 825YD REDUCED PRESSURE BACKFLOW PREVENTER
- - - CLASS 180 RING-TITE 3" PVC MAIN LINE PIPE
- - - CLASS 180,100 RING-TITE, & 200 PVC ZONE ZONE PIPE
- - - WATER SERVICE
- - - WIRE SPLICE BOX
- - - PVC SLEEVES

A3-BUILT NOTES

NOTES ON VALVES, QUICK COUPLERS, SPLICE BOXES, ISOLATION VALVES

A VALVES

A 10 18° north of pump house, 53° west of Wells St.
at Puddle Circle
A 01 valve location only 1° north of A10
A 21 53° north of pump house, 53° west of Wells St.
A 41 53° northeast of sleeve A10, 53° west of Wells St.
A 31 53° east of sleeve A10, 53° east of pump house,
by Wells St.
A 33 53° northwest of sleeve A10
A 23 53° northwest of sleeve A10, 53° south of Jewell St.
A 03 53° east of sleeve A10, 53° south of sleeve A15
A 91 53° east of sleeve A10, 53° east of sleeve A15
A 05 53° west of sleeve A10 at fire hydrant
A 113 53° north of A10, 53° west of sidewalk
A 103 53° north of A10, 53° west of sidewalk
A 123 53° west of electrical panel for stage, 53° south of sidewalk
A 133 53° west of electrical panel, 53° south of sidewalk
A 153 18° south of valve, 53° east of sleeve A10
A 163 53° southeast of sleeve A10
A 133 53° northeast of sleeve A10, 53° east of sidewalk
A 113 53° south of sidewalk, 53° east of Trinity St.
A 003 53° south of sidewalk, 53° east of Trinity St.

NOTES ON VALVES, QUICK COUPLERS, SPLICE BOXES, ISOLATION VALVES, USE PAINT WITH THESE INSTRUCTIONS.

3 VALVES

3 01 53° north of Elm St., 10° east of sleeve A2
3 02 53° north of Elm St., 10° east sleeve A2
3 21 53° north of Elm St., 10° east sleeve A2
3 31 53° north of Elm St., 20° east of sleeve A2
3 32 53° north of Elm St., 21° east of sleeve A2
3 43 53° north of Elm St., 53° east from the back of the reservoir
3 71 53° north of Elm St., 18° west from the front of the reservoir
3 72 53° east of Trinity, 53° south of 310
3 101 53° east of Trinity St., 10° east from sleeve A3
3 102 53° east of Trinity St., 10° east from sleeve A3
3 103 53° east of Trinity St., 10° east from sleeve A3
3 112 53° east of sleeve A3 and A5, 53° east of where the two walls come in together
3 121 these boxes are tied by A10
3 122 53° south off Jewell St., 53° east off Trinity St.
3 123 53° east off Jewell St., 53° east off Trinity St.
3 124 53° east off Jewell St., 53° east off Trinity St.
3 125 53° east off Jewell St., 53° east off Trinity St.

SPLICE BOXES

10° HOLLOW BOX

10° east of sidewalk, 53° east of sidewalk, 53° north of sidewalk
10° east of sidewalk, 53° east of sidewalk, 53° north of sidewalk
10° east of sidewalk, 53° east of sidewalk, 53° north of sidewalk
10° east of sidewalk, 53° east of sidewalk, 53° north of sidewalk
OUTLET COUPLERS

10° hollow box
on sidewalk preventer - irrigation side
on corner of Elm St., 10° east east of sleeve A1
on east of Trinity St., 53° east of sleeve A2
on northeast of sleeve A10, 53° south of sleeve A1
on northeast of sleeve A10, 53° south of sleeve A1
on northeast of sleeve A10, 53° east of sleeve A10, 53° east of sidewalk
located in sidewalk
located in sidewalk
18°
53° east of sidewalk at fire hydrant, 18° north of sidewalk
at corner of sidewalk
53° east of sidewalk, 20° east of sleeve A2
53° east of sidewalk, 20° east of sleeve A2
53° east of sidewalk, 20° east of sidewalk
53° east of sidewalk, 20° east of sidewalk

INSTALLED BY:

FOURNIER LANDSCAPE
CONTRACTORS

A3-BUILT DESIGN

JOB NAME:

IRRIGATION DESIGN

PLAN:

SCALE:

DATE:

DESIGNER:

15-JUN-00

DRAFT

REVISION

1-30'

1-10'

1-5'

1-1'

DESIGNER:



Turf products corporation
157 Moody Road, Enfield, CT 06042
(860) 783-3531, (800) 783-3531