

BOOK RETURN

UH-2

LOADING PLATFORM

DISCONNECT WITH PILOT LIGHT FOR HEATER STRIPS. SEE DETAIL.

PUSH BUTTON STATION WITH PILOT LIGHTS FOR CONTROL OF FANS - SEE DETAIL.

SUPT. OFFICE

JANITOR LOCKER ROOM

LECTURE ROOM

PHOTO AB

PHOTO N-8

WOMEN'S

MEN'S

WATER COOLER

LOBBY

CLOAK ROOM

UNIT HEATER AT CEILING

TRUSS AREA UNDER TERRACE

DUCT SPACE

NOTE: USE THIS SPACE FOR FEEDERS TO PANELS ON SOUTH SIDE

24" x 12" x 4" TELEPHONE PULL BOX

10" x 10" x 6" FIRE ALARM PULL BOX

2-EMPTY 3" CONDUITS ONE BY ELECTRICAL CONT'R. ONE BY S.N.E. TELEPHONE CO.

APPROXIMATE 150' TO TELEPHONE MANHOLE.

TO LT. BELOW

TO LT. ABOVE

TO CIRCITS 12 & 13

L.R. "1" 18"

2-12-2" FIRE ALARM MASTER BOX

STUB UP FOR LIGHT STANDARD

TO LP "BH."

STUB UP FOR LIGHT STANDARD

TO LP "BH."

MAIN FLOOR

BASEMENT

TYPICAL BAY LOOKING EAST-WEST STACK AREA SHOWING "K" FIXTURES

SCALE 1/4" = 1'-0"

BASEMENT PLAN ELECTRIC

SCALE: 1/8" = 1'-0"

SCHUTZ & GOODWIN ARCHITECTS  
12 HAYNES STREET, HARTFORD, CT  
JOB NO. 53-1A DATE 6/15/54  
DRAWN BY V.Z.

SCALE:  $\frac{1''}{8'} = 1' - 0''$

<b>SCHUTZ &amp; GOODWIN</b> <b>ARCHITECTS</b> <b>12 HAYNES STREET HARTFORD, CONN.</b>	
JOB NO.	DATE <u>6/15/54</u>
<b>53-1A</b>	DRAWN BY <u>V.Z.</u>
SHEET NO.	TRACED BY <u>O.R.I.</u>
<b>55</b>	CHECKED BY <u>V.Z.</u>
<b>BUILDING FOR</b> <b>THE HARTFORD PUBLIC LIB</b> <b>CITY OF HARTFORD - OWNED</b>	